



## Associated documents

Installation guidelines, dated 25.04.2022.

## Control

The factory production control (FPC) is monitored by an independent inspection body.  
Control plan: Ref no. 210-21-0152 dated 2021-11-18, Inspection body: RISE

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this type approval and associated documents. Further the product shall be accompanied by a manufacturer's assurance, certifying that the product has been manufactured in accordance with the documents on which this type approval is based.

## Manufacturing place

Production control includes the following place:  
EIROPLASTS SIA, 32/6 Granita Street, LV-2119 Acone, Latvia

## Marking

The products are to be marked at the factory. The marking consists of a label on every product supplied and includes:

Holder	EIROPLASTS SIA
Manufacturing place	32/6 Granita Steet, LV-2119, Acone, Latvia
Product type designation	EUROPLAST
Date of production	date
Type approval number	C900551
Tightness class	D
Dimension $\varnothing$ mm	x mm
Boverket's registered trade mark	
RISE Accreditation number	1002
Certification body and Inspection body	RISE

## Basis for approval

Test report P112392B and inspection report P112392A from RISE.

## Comments

The products are tested according to EN 12237:2003 with the headline: "Ventilation for buildings – Ductwork – Strength and leakage of circular sheet metal ducts". The ducts fulfill tightness class D (2000 Pa overpressure and – 750 Pa negative pressure). Coating Z275 meets corrosion class C3 according to AMA VVS & Kyla 2019.

Associated documents shall accompany the product or by other means be available to users of the product.

## Validity

Valid through 2027-05-02.

Validity of this type approval can be verified on our website.

The validity of this type approval expires when the type approved products with the intended use according to this type approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.

A handwritten signature in blue ink, appearing to read 'Stefan Coric'.

Stefan Coric

*This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish text shall take precedence.*